

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: BDO/ST/156

Dated: 14/5/2026

It is certified that an inspection team headed by SHAH FAIZ, (PAA),
(Name of Officers with designation) from **JAMMU AND KASHMIR RURAL DEVELOPMENT
DEPARTMENT (BLOCK DEVELOPMENT OFFICE TREHGAM)** MES/ Cantonment Board/ PHED/Local
Bodies inspected the **HAJIPIR ARMY GOODWILL SCHOOL TREHGAM**, (Name & Address of the
school) on 14-05-2026, (date of inspection) and on the basis of Water Test Report (Attached)
bearing no 204/JJM/SDWTL/26 dated 5th of May 2026 (MES/ Cantt Bd/ PHED Lab) issued by **WATER
TESTING LABORATORY (DEPARTMENT OF J&K PUBLIC HEALTH ENGINEERING SUB DIVISION
KRALPORA)** certified that the **HAJIPIR ARMY GOODWILL SCHOOL TREHGAM** (Name of school)
has safe drinking water facilities for the students and members of staff of the institution. School also
maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed
by the Central/ State/ U.T. Govt/ Indian Army

This certificate is valid till one year

Signature with Seal:

Name

:

Hakeem Agib. Jauhal

Designation

:

BDO, Trehgam

Name & Address of the Office / Department:

RDD,
BDO Trehgam

To

**HAJIPIR ARMY GOODWILL SCHOOL
TREHGAM KUPWARA
JAMMU AND KASHMIR
(Name & Address of the Institution)**

**Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies/ MES
Authority/ Cantonment Board**

Principal
Hajipir Army Goodwill School
Trehgam (Kup)



SANITATION AND HYGIENE CERTIFICATE

Certified that **Hajipir Army Goodwill School Trehgam** has been inspected by the duly constituted inspection team of Block Medical Office Trehgam. During the inspection, the school was found maintaining satisfactory sanitation and hygiene conditions within the premises. Safe drinking water facilities, functional toilets, proper waste disposal system, and overall hygienic environment were found satisfactory as per prescribed public health and safety standards.

On the basis of the positive inspection report submitted by the inspection team, this Sanitation and Hygiene Certificate is hereby issued to the institution for the purpose of CBSE registration/affiliation.

No:-BMOT/NHM/2026-27/1083
Date:-07-05-2026

Block Medical Officer
Trehgam
07/05/26

Principal
Hajipir Army Goodwill School
Trehgam (Kup)

WATER TESTING LABORATORY

PHE SUB-DIVISION KRALPORA

Source: Bore-well
 Village/Block: Trehgam / Kralpora
 (opposite Tehsil office)
 Status: Raw-water
 Forwarded/ collected by/Name: Shareel Ah. Sheikh

Scheme: - Nil -
 Place of collection: Hajipir Army Goodwill School Trehgam
 Date of Receipt: 05/05/2026
 Date of Examination: 05/05/2026
 No. 204 / JIM / SDWT / 26

S. No	Parameters	Units	Desirable/Permissible Limit	Result
01	Fluoride	Mg/l	0.1-0.5	0.0
02	Odour & Taste		Unobjectionable	Unobjectionable
03	Chloride (as Cl)	Mg/l	200	40
04	Total Hardness (as CaCO ₃)	Mg/l	250-1000	240
05	Total Iron	Mg/l	0.3-1.0	0.0
06	Nitrate	Mg/l	0-45	0.0
07	PH at 25C	Mg/l	6.5-8	7.6
08	Residual Chlorine	Mg/l	0.2-1.0	- Nil - (0.0)
09	Conductivity	uS	-	480.9
10	TDS (Total Dissolved Salts)	PPM	500-2000	392.9
11	Turbidity	NTU	1.0-5.0	0.65
12	colour		5-15	< 5
13	Bacteriological H ₂ S	MPN	Zero	Zero
14	Ammonia	Mg/l	0.0	0.0

Final Impression:- Water is free from physio-chemical as well as bacteriological contamination as per the above few tested parameters. However boiling/ disinfection is essential before using for drinking

[Signature]
 Lab. Assistant

[Signature]
 Principal
 Hajipir Army Goodwill School
 Trehgam (Krip)

Incharge
 Sub Division Water Testing Lab
[Signature]
 Microbiologist